

	Raw Sewage	Treated Wastewater	Venice Gardens Lakes
Total Nitrogen (mg/l)	61	9.6	2.8
TKN (mg/l)	62	0.9	2.8
Nitrate + Nitrite (mg/l)	0.07	8.6	<0.004
Ammonia (mg/l)	42	0.4	<0.008
Total Phosphorus (mg/l)	8.4	1.4	0.2
Biochemical Oxygen Demand (mg/l)	217	<3	10.9
Total Suspended Solids (mg/l)	326	0.6	56.7
Fecal Coliform Bacteria (cfu/100ml)	10,000,000	<1	160
Enterococci (cfu/100ml)	460,000	<1	no data available
E. coli (cfu/100ml)	8,000,000	<1	no data available